



# Winter Paving Plan

For Engineering / Right-of-Way Permits



## ASPHALT ROAD - COLD PATCH

ENG PERMIT #		
JOB ADDRESS:		
CONTRACTOR:		
TEMP PATCH	COLD PATCH?	Y    N
INSTALL DATE:		

INITIALS  
REQUIRED

Cold patch must be regularly checked and maintained by contractor throughout the winter months until a permanent patch is installed. If the patch is damaged or destroyed, it must be replaced by contractor immediately.

Patch must be flush to the road surface when installed. If the patch is raised above the road surface and causes damage to city snow-removal equipment, contractor shall be held liable for damages.

## ASPHALT ROAD - PERMANENT PATCH

ASPHALT PLANT:	
PAVING SUB:	
COMPACTION TESTS BY:	
<b>PERMANENT PATCH MUST BE PLACED BY MAY 22, 2026</b>	
ANTICIPATED INSTALL DATE:	

## WINTER CONCRETE SPECS

**WINTER CONCRETE MIX IS REQUIRED FROM NOV 17, 2025 TO APRIL 17, 2026.**

(ANY EXCEPTIONS TO DATE RANGE MUST BE APPROVED BY THE CITY ENGINEER)

**WINTER MIX IS A 7 1/2 BAG MIX, AND IS RATED AT 5,000 PSI OR GREATER.**

**HEATED BLANKETS & OTHER COLD-WEATHER PROTECTIVE MEASURES MAY BE REQUIRED.**

**REFER TO THE APWA SECTION 03 30 10 3.4, PART C - COLD WEATHER PLACEMENT**

## HOT MIX STANDARDS

<b>MIX DESIGN:</b>	1/2" 50 Gyration, PG-58-28 Max. recycled asphalt cannot exceed 15%
<b>LIFT THICKNESS:</b>	<b>MIN: 2"</b> <b>MAX: 4"</b>
<b>AIR TEMP (°F)</b>	50° F in the shade and rising by 10:00am
<b>ASPHALT TEMP (°F)</b>	285° F (Min) - 2" Lift 265° F (Min) - 3 & 4" Lift

\*Any material placed as a pavement patch that does NOT meet the above specified requirements will be considered "temporary".

By signing this document, Contractor acknowledges that the permanent patch must be placed in compliance with Ogden City Standards, by the "anticipated" date shown. If permanent patch has not been installed by "anticipated" date, contractor will be notified by phone and/or email. If contractor is unreachable or unresponsive by **Friday, May 22, 2026**, the License and Permit bond associated with this job will be exercised and Ogden City will engage another contractor to finish the work. This will negatively affect the Contractor's bond rating and ability to obtain permits with Ogden City in the future.